



RECEIVED

MAR 26 2004

CITY OF BLYTHE DEV. SER.

File
3-26-04
D.C.

James G. Holt, P.E.
Robert K. Holt, P.E.
Kenneth G. Skillman, III, P.E., L.S.

Engineering

Planning

Surveying

March 25, 2004

Ms. Jennifer Wellman
Director of Development Services
City of Blythe
235 North Broadway
Blythe, Calif. 92225

COPY

**RE: TRACT NO. 28758-1
P-JAN CONSTRUCTION
THG PROJECT NO. 599.007**

Dear Jennifer:

An elevation check of a building pad for the above referenced tract on 03/21/04 revealed the following data:

<u>LOT NO. 25</u>	<u>DESIGN ELEVATION</u>	<u>ACTUAL ELEVATION</u>
SW QUADRANT	274.10	274.07
NW QUADRANT	274.10	274.15
NE QUADRANT	274.10	274.16
SE QUADRANT	274.10	274.08

The elevation check is within the +/- 10 ft. City of Blythe tolerance. The pad has been satisfactorily constructed in accordance with the approved grading plan.

Should any questions arise concerning this matter, please contact us.

Sincerely,

Robert K. Holt, P.E.



Cc: William Brunet, P.E., City Engineer, Public Works Dept.
P-Jan Construction
Roger Snellenberger Development Corporation